

**Sub Divisional Level Water Quality Testing and Monitoring Laboratory**  
**Uttarakhand Jal Sansthan, Vikasnagar.**  
 Ph (O): 9258186962, E-mail: jalkallab@gmail.com

Form ID: 94/UJS/SDLWQTML/2025-26

Dated: 06/05/2025

**WATER QUALITY TEST REPORT**

Name and Address of Organization/ Customer		Shri Guru Ram Rai Public School Sahaspur	
Product Description (Surface Water/ Ground Water/ Drinking Water)	Drinking Water	Sample Description	One Water Sample Collected From <b>Shri Guru Ram Rai Public School</b>
Reference Sample Identification:	SDLWQTML/UJS/2025-26-94		Date of Start of Analysis:05/05/2025
			Date of End of Analysis:06/05/2025
Date and Time of Sample Received:05/05/25& 12:10 PM	Sample Collected by:	Customer	

SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1	Total Coliform,MPN/100ml	Absent	Absent	Absent	APHA 23 rd Ed.-9223-B
2	E.Coli,MPN/100ml	Absent	Absent	Absent	APHA 23 rd Ed.-9223-B
3	Residual Free Chlorine,mg/L	0.0	0.2	1.0	IS 3025Pt-26:1986

*N. Rawal*  
 Manager  
 S.G.R.R. Public School  
 Sahaspur (D.Dua)

(Er.J.S.Chauhan)  
 Quality Manager  
 SDWQML LAB  
 Uttarakhand Jal Sansthan  
 Vikasnagar

-End of Report-

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.



**NABL Recognized**  
**Sub Divisional Level Water Quality Testing and Monitoring Laboratory**  
**Uttarakhand Jal Sansthan, Vikasnagar**  
**Government Drinking Water Testing Laboratory**  
 Ph (O): 01360-250345, E-mail: jalkallab@gmail.com

Test Report ID: 94/UJS/SDLWQTML/2025-26

Dated: 06/05/2025

**WATER QUALITY TEST REPORT**

Name and Address of Organization/ Customer		Shri Guru Ram Rai Public School Sahaspur		
Product Description (Surface Water/ Ground Water/ Drinking Water)		Drinking Water	Sample Description	One Water Sample collected from <b>Shri Guru Ram Rai Public School</b>
Reference Sample Identification:		SDLWQTML/UJS/2025-26-94		Date of Start of Analysis:05/05/2025 Date of End of Analysis:06/05/2025
Date and Time of Sample Received:05/05/25 & 12:10PM		Sample Collected by:		Customer

SN	Water Quality Parameters Under Chemical cScope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1.	pH	6.62	6.5 to 8.5	No Relaxation	IS 3025 Pt-11, 2022
2.	Total Dissolved Solids (TDS), mg/L	72	500	2000	IS 3025 Pt-16-2023
3.	Turbidity, NTU	0.29	1	5	IS 3025 Pt-10-2023
4.	Total Alkalinity (as CaCO <sub>3</sub> ), mg/L	62	200	600	IS 3025 Pt-23: 2023
5.	Total Hardness (as CaCO <sub>3</sub> ), mg/L	50	200	600	IS 3025 Pt-21: 2009 Ra,2019
6.	Chloride, mg/l	4.99	250	1000	IS 3025 Pt-32 : 2019
7.	Calcium (as Ca), mg/L	11.2	75	200	IS 3025 Pt-40 : 2023
8.	Magnesium (as Mg), mg/L	5.34	30	100	APHA 23rd Ed.-3500-Mg B: 2023
9.	Colour, Hazen	01	5	15	IS 3025 Pt-04 : 2021
10.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 Pt-05 : 2022
11.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 Pt-08 : 2012

*V. Rawal*  
 Manager  
 S.G.R. Public School  
 Sahaspur (D. Dist)

(Er. J.S. Chauhan)  
 Quality Manager  
 SDWQTML LAB  
 Uttarakhand Jal Sansthan,  
 Vikasnagar

-End of Report-

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by S.D.L.W.Q.T.M.L, UJS, VIKASNAGAR

(Name of Officers with designation) from Er. Alendra Singh (J.E)

(Name of Department/ Office) inspected the SDLW.Q.T.M.L, UTTARAKHAND Jal SANSTHAN, VIKASNAGAR

(Name & Address of the school) on 05/05/25 (date of inspection) and found that the

Shri Guru Ram Rai Public School, Sahaspur (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of six month

Signature with Seal

Alendra Singh  
Authorized Signatory

SDLWQTM.L, UJS, Vikasnagar

Name

Alendra Singh

Designation

J.E

Name & Address of the Office / Department : UTTARAKHAND

Jal Sansthan, Vikasnagar

To

Principal, S.G.R.R. Public

Sahaspur

(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

V Rawal

Manager  
S.G.R.R. Public School  
Sahaspur (D. Dist)

Alendra Singh  
Principal  
S.G.R.R. Public School  
Sahaspur